

City of Bisbee Amendments to the 2023 Edition of the National Electrical Code

1. Article 210.8 (B)(5). Amend to read: “Rooftops. The receptacle(s) shall have the reset located on the roof.”
2. Article 210.8 (6). Amend title to read: “Kitchens / Bars / Beverage Dispensary areas.”
3. Article 210.11 (4) insert (5) Amend by adding this new section “Where required smoke alarms and carbon monoxide alarms shall not be installed on a dedicated circuit and shall originate from a general-purpose branch circuit.
4. Article 230.70A. Amend by adding the following after the first paragraph: “Service disconnecting means and risers shall be surface mounted, a recess service entry is not permitted.”
5. Article 250.50. Amend by adding the following: “All accessory structures with a poured foundation require the installation of a concrete-encased electrode as required by NEC 250.52 (A)(3) and IRC Section E3608.1.2.”
6. Article 300.21. Amend by adding the following: “Penetrations of one-hour fire resistance-rated walls shall require approved metallic raceway with 12-inch extensions on both sides of the wall. The penetrations of the wall and the conduit ends shall be fire safe. Penetrations of two-hour, or greater, fire-resistance-rated walls shall require approved metallic raceway with 5-foot extensions on both sides of the wall. The penetrations of the wall and the conduit ends shall be fire safe.”
7. Article 408. Amend by adding a new sub-Article 408.31, Subpanels and Low-Voltage Boxes, to read as follows: “Subpanels and low-voltage boxes shall not be located in any firewall, fire barrier, fire partition, or in the garage side of the common wall separating the dwelling from a garage or carport. Subpanels and low-voltage boxes may be surface mounted on any of the above-mentioned walls.”