

City of Bisbee Amendments to the 2024 Edition of the International Fuel Gas Code

1. At Section 101.1, insert City of Bisbee.
2. At Section 101.2, number the existing exception as Exception 1 and add Exception 2, to read as follows: “As an alternative to the provisions of this code, fuel gas piping systems, fuel-gas utilization equipment and related accessories in existing building undergoing repair, alteration, or addition, and change of occupancy shall be permitted to comply with the International Existing Building Code.”
3. At Section 106.6.2, add: “City of Bisbee building permit fees shall be as established in the City Code.
4. At Section 303.7, insert new subsection 303.7.1 to read: “Liquefied petroleum gas piping shall not serve any gas appliance located in a pit or basement where heavier-than-air gas might collect to form a flammable mixture.”
5. Appendices A, B, and C are adopted. Appendix D is not adopted.