

City of Bisbee Amendments to the 2024 Edition of the International Mechanical Code

1. At Section 101.1, insert City of Bisbee.
2. At Section 101.2, number the existing exception 1. Add Exception 2, to read:
“Mechanical systems in existing buildings undergoing repair, alteration, or addition, or change of occupancy shall be permitted to comply with the International Existing Building Code.”
3. At Section 103.1, insert Building Safety Department.
4. At Section 309, insert a new Section 309.2: Space-cooling systems; Interior spaces intended for human occupancy shall be providing with cooling systems capable of maintaining a maximum indoor temperature of 85°F (29°C).
5. At Section 505.3, strike exception 1
6. Appendix A is adopted. Appendix B, C, D, and E are not adopted.